



PREJAZD KABINY	: 85 mm
STLACENIE NARAZNIKA KABINY	: 66 mm
CELKOM	: 151 mm
NADSKOCENIE KABINY	: 35 mm
PREJAZD VYVAZOVACIEHO ZAVAZIA	: 79 mm
STLACENIE NARAZNIKA VYVAZOVACIEHO ZAVAZIA	: 66 mm
CELKOM	: 180 mm

MAIN STANDARD:			COMPLEMENTARY STANDARDS:		
EN81-20			EN81-73_2020		
Odchylky:			Odchylky:		
Postup pre ES posudenie zhody			CAP2 EU-type examined model lift		
VELKOST HLAVY SACHTY & PRIEHLBNE					
re : PODLA NORMY					
ODSTAVEC EN81-20		SKUTOCNOST		MINIMUM EN81-20	
Hlava sachty	1.	5.2.5.6.2	607	100	
	2.	5.2.5.7.2 (c1)	300	300	
	3.	5.2.5.7.2 (a)	897	500	
	4.	5.2.5.7.2 (b)	837	100	
	5.	5.2.5.6.2	193	100	
	6.	5.2.5.7.1	Refuge space 0.5x0.7x1.0m		
	7.				
Priehľben	8.	5.2.5.8.1	Refuge space 0.7x1.0x0.5m		
	9.	5.2.5.8.2 (a)	530	500	
	10.	5.2.5.8.2 (a)	534	500	
	11.	5.2.5.8.2 (a1)	109	100	
	12.	5.2.5.8.2 (a2)	660	100	
		Nazov projektu			
		psychiatrická nemocnica Pezinok			
		Adresa umiestnenia výtahu			
		V1			
		Nazov vykresu			
		VYKRES PRE POSUDENIE ZHODY			
		Cislo výtahu			
Cislo zakazky	Cislo vykresu			Zmena	Strana
	Cust no	-		-	1 (1)