

## Príloha protokolu č.283MM2023

Č.m.	Účel miestnosti	Vonkajšie vplyvy																Využitie				Konštruk. budov	Norma, popis	
	Priestor	Klasifikácia vonkajších vplyvov																Klasifikácia využit.				Charakter.		
		AA	AB	AC	AD	A <sub>E</sub>	A <sub>F</sub>	AG	AH	AK	AL	AM	AN	AP	AQ	AR	AS	BA	BC	BD	BE	CA	CB	
101	Zádverie	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	
102	Chodba	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	
103	Chodba	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	
104	Kancelária	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	
105	Kancelária	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	
106	Kancelária	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	
107	Kancelária	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	
108	Sklad PB	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	
109	Kancelária	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	
110	Sklad	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	
111	WC M	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	STN 33 2000-7-701
112	WC M	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	STN 33 2000-7-701
113	WC IM	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	STN 33 2000-7-701
114	WC Ž	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	STN 33 2000-7-701
115	WC Ž	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	STN 33 2000-7-701
116	Sprcha	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	STN 33 2000-7-701
117	Upratovanie	5	5	1	1	1	1	1	1	1	1	1	1	1	1	1	N	1	2	1	1	1	1	STN 33 2000-7-701
Vonkajšie prostredie																								
	Okolie	8	8	1	N	1	2	1	1	1	1	1	2	1	1	2	1	1	2	1	1	1	1	AD – dážď atmpoferického pôvodu

N-nevyskytuje sa