




Operator
Telephone
Fax
e-Mail

Kancelaria 2,19 / Summary



Height of Room: 2.800 m, Mounting Height: 2.800 m, Maintenance factor: 0.67

Values in Lux, Scale 1:52

Surface	ρ [%]	E _{av} [lx]	E _{min} [lx]	E _{max} [lx]	u0
Workplane	/	593	473	647	0.798
Floor	20	435	289	560	0.665
Ceiling	70	110	78	154	0.706
Walls (4)	50	243	107	358	/

Workplane:

Height: 0.750 m
Grid: 32 x 32 Points
Boundary Zone: 0.500 m

UGR

Left Wall
Lower Wall
(CIE, SHR = 1.00.)

Lengthways-

16
16

Across

16
16

to luminaire axis

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.426, Ceiling / Working Plane: 0.185.
Proportion of points with less than 400 lx (for IEQ-7): 0.00%.

Luminaire Parts List

No.	Pieces	Designation (Correction Factor)	Φ (Luminaire) [lm]	Φ (Lamps) [lm]	P [W]
1	4	LEDVANCE GmbH 4058075440432 PL PFM 600 36W 4000K UGR19 4320LM (1.000)	4320	4320	36.0
Total:			17280	17280	144.0

Specific connected load: 9.00 W/m² = 1.52 W/m²/100 lx (Ground area: 16.00 m²)