


3+N+PE st. 50Hz 400/230V / TN-C-S



EXIPOT. SKRINKOVNICA

PRIVOD	CENTRAL STOP	UZEMNENIE	UZEMNENIE	UZEMNENIE	UZEMNENIE	UZEMNENIE	UZEMNENIE	UZEMNENIE	UZEMNENIE	1	2	3	4	5	6
WLRH1	WLSB-STOP	WUHAS	WLEP-RK1	WLEP-RACK	WLEP1	WLEP2	WLEP3	WLEP-RH2	WLRK1	WU2	WU3	WU4	WU5	WU6	
CNK-J 4x70	CHKE-R-J 3x1,5	Fedn D10	HD7-V-K 35 z/2	HD7V-K 16 z/2	HD7V-U 6 z/2	HD7V-U 6 z/2	HD7V-U 4 z/2	HD7V-K 16 z/2	1-CNKE-R 4x50	1-CNKE-R 5x6	1-CNKE-R 5x6	1-CNKE-R 5x6	CNY-J 5x16	CHKE-R-J 3x2,5	

POLE 1
600x1200x300mm

RE1	SB-STOP	HUS	EP-RK1	EP-RACK	EP1	EP2	EP3	EP-RH2	RK1	ZS102	103	104	105	RACK
ROZVADZAC ELEKTROMEROVY	CENTRAL STOP	UZEMNENIE	POSYLANIE ROZVADZAC KUCHENNA	POSYLANIE ROZVADZAC RACK	POSYLANIE TERELNE CERPAVOLO	POSYLANIE BOLLER	POSYLANIE SPRACHA	POSYLANIE ROZVADZAC PRIPRAVA	ROZVADZAC KUCHENNA 106,0kW	ZS102 2,00kW ZS102kW SKRINA	VYVOD 400V 1,00kW PRIPRAVA	VYVOD 400V 1,00kW PRIPRAVA	NABAJANIE AUTOMOBILOV 10,00kW 0,10kW	ROZVADZAC RACK

Vyracoval:	A.BRISUDA	AKCE:	Pristavba zgladiadnej školy	Investor:	Obec Suchá nad Parnou	Zak.číslo:	EL2021-85	AK.:	2021	Listů:	7
Kontroloval:	ING.J.BRISUDA		Suchá nad Parnou	Obsch:	ROZVADZAC RH1	Změň/Datum:		V.č.:	505	List:	3
Datum :	12/2021					Měřtko:	N				