



Luminaire list (Building 1, Storey 1)								
Index	Manufacturer	Article name	Item number	Fitting	Luminous flux	Maintenance factor	Connected load	Quantity
1	TRILUX	E-Line 7651 LW 80-840ETDD L225 01		1x 1 x LED ETDD	8400 lm	0.80	46 W	12
2	TRILUX	ELINE LN 150 840 L225 1 20		1x 1 x LED ET/ETDD	15800 lm	0.70	98 W	46
3	TRILUX	ELINE LW 55 840 L150 1 20		1x 1 x LED ET/ETDD	5800 lm	0.80	31 W	3

#	Name	Parameter	Min	Max	Average	Min/average	Min/max
1	Calculation surface 3	Perpendicular illuminance	601 lx	891 lx	661 lx	0.91	0.67
2	Calculation surface 2	Perpendicular illuminance	543 lx	859 lx	620 lx	0.88	0.63
3	Calculation surface 1	Perpendicular illuminance	551 lx	847 lx	621 lx	0.89	0.65
4	Calculation surface 4	Perpendicular illuminance	485 lx	601 lx	563 lx	0.86	0.81
5	Calculation surface 5	Perpendicular illuminance	484 lx	613 lx	573 lx	0.84	0.79
6	Calculation surface 6	Perpendicular illuminance	507 lx	617 lx	566 lx	0.87	0.82
7	Calculation surface 7	Perpendicular illuminance	544 lx	631 lx	612 lx	0.89	0.86
8	Working plane (Room 1)	Perpendicular illuminance (Adaptive)	265 lx	879 lx	582 lx	0.46	0.30
9	Working plane (Room 2)	Perpendicular illuminance (Adaptive)	879 lx	2005 lx	1607 lx	0.55	0.44