

HYDEOTECHNICKÉ PARAMETRE VODOVODNEJ SIETE - 1. TLAKOVÉ PÁSMO POŽIARNA POTREBA VODY = 7,50 l/s

UZLOVÝ BOD	KÓTA			TLAK		ÚSEK	DN	DĹŽKA	PRIETOK	RÝCHLOSŤ	SPÁD TL. ČIARY	STRATY PO DĹŽKE
	TERÉNU	MAX. HYDROSTAT. TLAKU	HYDRODYNAM. TLAKU	MAXIMÁLNY HYDROSTATAT.	HYDRODYNAM.							
	m n.m.	m n.m.	m n.m.	m	m		mm	m	l/s	m/s	‰	m
1	231,60	233,00	229,600			1	100	342,90	7,50	0,955	17,96	6,159
2	201,69	233,00	223,441	31,31	21,751	2	100	51,40	7,50	0,955	17,96	0,923
3	201,71	233,00	222,518	31,29	20,808	3	100	720,70	4,11	0,523	5,39	3,888
4	183,87	233,00	218,618	49,13	34,748	4	100	328,50	3,39	0,432	3,67	1,206
5	179,04	233,00	219,824	53,96	40,784	5	100	149,50	3,39	0,432	3,67	0,549
6	180,32	233,00	220,373	52,68	40,053	6	100	584,50	3,39	0,432	3,67	2,145
7	193,73	233,00	215,180	39,27	21,450	7	100	191,40	7,50	0,955	17,96	3,438