

HYDEOTECHNICKÉ PARAMETRE VODOVODNEJ SIETE - 2. TLAKOVÉ PÁSMO POŽIARNA POTREBA VODY = 7,50 l/s

UZLOVÝ BOD	KÓTA			TLAK		ÚSEK	DN	DĹŽKA	PRIETOK	RÝCHLOSŤ	SPÁD TL. ČIARY	STRATY PO DĹŽKE
	TERÉNU	MAX. HYDROSTAT. TLAKU	HYDRODYNAM. TLAKU	MAXIMÁLNY HYDROSTATAT.	HYDRODYNAM.							
	m n.m.	m n.m.	m n.m.	m	m		mm	m	l/s	m/s	‰	m
1	222,80	237,30	234,30			1	100	469,60	7,50	0,955	17,96	8,435
2	213,40	237,30	225,865	23,90	12,465	2	100	279,70	4,39	0,559	6,15	1,721
3	211,95	237,30	224,144	25,35	12,194	3	100	186,90	4,39	0,559	6,15	1,150
4	198,34	237,30	222,994	38,96	24,654	4	100	381,40	3,11	0,396	3,08	1,178
5	195,96	237,30	223,413	41,34	27,453	5	100	51,30	3,11	0,396	3,08	0,158
6	188,25	237,30	224,111	49,05	35,861	6	100	135,20	3,11	0,396	3,08	0,418
7	190,00	237,30	224,529	47,30	34,529	7	100	226,10	3,11	0,396	3,08	0,698
8	191,27	237,30	224,687	46,03	33,417	8	100	141,60	3,11	0,396	3,08	0,437
10	201,69	237,30	219,241	35,61	17,551	9	100	208,96	7,50	0,955	17,96	3,753