

HYDEOTECHNICKÉ PARAMETRE VODOVODNEJ SIETE - 1. TLAKOVÉ PÁSMO
MAX.DODÁVKA VODY Z ATS = 6,42 l/s, t.j.
PRI PRÁCI 3 ČEPADIEL

UZLOVÝ BOD	KÓTA			TLAK		ÚSEK	DN	DĹŽKA	PRIETOK	RÝCHLOSŤ	SPÁD TL. ČIARY	STRATY PO DĹŽKE
	TERÉNU	MAX. HYDROSTAT. TLAKU	HYDRODYNAM. TLAKU	MAXIMÁLNY HYDROSTATAT.	HYDRODYNAM.							
	m n.m.	m n.m.	m n.m.	m	m		mm	m	l/s	m/s	‰	m
1	231,60	258,00	254,60			1	100	170,30	6,42	0,955	17,96	2,242
2	212,75	258,00	252,358	45,25	39,608	2	100	268,00	6,42	0,955	17,96	3,527
3	219,41	258,00	248,831	38,59	29,421	3	100	360,30	6,42	0,955	17,96	4,742
4	210,08	258,00	244,089	47,92	34,009							