

HYDEOTECHNICKÉ PARAMETRE VODOVODNEJ SIETE - 1. TLAKOVÉ PÁSMO POŽIARNA POTREBA VODY = 7,50 l/s - OBTOK ATS

UZLOVÝ BOD	KÓTA			TLAK		ÚSEK	DN	DĹŽKA	PRIETOK	RÝCHLOSŤ	SPÁD TL. ČIARY	STRATY PO DĹŽKE
	TERÉNU	MAX. HYDROSTAT. TLAKU	HYDRODYNAM. TLAKU	MAXIMÁLNY HYDROSTATAT.	HYDRODYNAM.							
	m n.m.	m n.m.	m n.m.	m	m		mm	m	l/s	m/s	‰	m
1	231,60	233,00	229,60			1	100	170,30	7,50	0,955	17,96	3,060
2	212,75	233,00	226,540	20,25	13,790	2	100	268,00	7,50	0,955	17,96	4,814
3	219,41	233,00	221,726	13,59	2,316	3	100	360,30	7,50	0,955	17,96	6,472
4	210,08	233,00	215,254	22,92	5,174							