

Napäťová sústava:
3NPE ~ 50Hz 400V/230V, TN-S

Ochrana pred nebezpečným dotykovým napätím (STN 33 2000-4-41: 03.2019)
základná ochrana (priamy dotyk) podľa čl.411.2 prílohy „A“:

- krytmi - A.2
- izoláciou - A.1

pri poruche (nepriamy dotyk) podľa čl.411.3:

- ochranným uzemnením čl. 411.3.1.1
- ochranným pospájaním čl.411.3.1.2
- samočinným odpojením pri poruche čl.411.3.2 v sieti TN

doplňková ochrana

- doplnkové ochranné pospájanie čl. 415.2
- prúdovým chráničom čl.415.1

	POZOR ELEKTRICKÉ ZARIADENIE
	HLAVNÝ VYPÍNAČ
	VYPNI V NEBEZPEČENSTVE
	NEHAS VODOU ANI PENOVÝMI PRÍSTROJMI

Špecifikácia rozvádzača:

Pilierová skriňa so zmným dielom,
(HASMA OS 26x60 - F263+VEZ)

Rozmery (vxšxh): 600x260x245

Prívod : zdola; Vývody : dole

Un=400/230V; IP44/IP20; In=20A, Ik''=10kA; ip=11,88 kA

ČÍSLO LISTU	OBSAH	REVÍZIA						
		0	1	2	3	4	5	6
1	TITULNÝ LIST	0						
2	PRÍVOD, OCHRANA PROTI PREPÄTIU, VÝVODY, ZÁSUVKY	0						
3	OSVETLENIE	0						
4	REZERVA	0						
5	REZERVA	0						
6	REZERVA	0						
7	REZERVA	0						
8	REZERVA	0						
9	REZERVA	0						
10	ZOSTAVA	0						

REVÍZIA :	DÁTUM :	MENO :	KRESLIL :	DÁTUM :	MENO :	PROJEKT: 2024-029 Centrum kultúrneho dedičstva Kostolná, p. č. 56/1, 56/2, 57/1, 57/2, 66/1, 69/1, 77 SO 06 Studňa pre závlah. vodu Obec Kostolná pri Dunaji, 903 01 Kostolná pri Dunaji 59	NÁZOV VÝKRESU : Rozvádzač R4 SO 06 Studňa pre závlah. vodu	LINKA :	
REVÍZIA :	DÁTUM :	MENO :	KONTROLOVAL :	DÁTUM :	MENO :			LISTOV : 10 LIST : 1	
REVÍZIA :	DÁTUM :	MENO :	DUEL-ELEKTROSYSTÉM,s.r.o MALACKY					ČÍSLO VÝKRESU :	
REVÍZIA :	DÁTUM :	MENO :						E13	
REVÍZIA :	DÁTUM :	MENO :							

The diagram shows a floor plan of a building with a total width of 1000 units, divided into sections 10-A through 10-J. The layout includes a large open area on the left, a central corridor, and a series of rooms on the right. Key features include:

- Dimensions:**
 - Section 10-A: 520 units wide.
 - Section 10-D: 110 units wide.
 - Section 10-E: 250 units wide.
 - Section 10-F: 250 units wide.
 - Section 10-G: 600 units wide.
 - Section 10-H: 245 units wide (indicated by a diagonal dimension line).
 - Section 10-I: 260 units wide (indicated by a vertical dimension line).
- Rooms and Features:**
 - 10-A:** Large open area.
 - 10-D:** Small rectangular room.
 - 10-E:** Large rectangular room.
 - 10-F:** Large rectangular room.
 - 10-G:** Contains a vertical strip labeled 'N' and 'PE', a large rectangular room, and a smaller room labeled 'FV0'.
 - 10-H:** Contains a large rectangular room, a smaller room labeled 'SA0', and a room labeled 'F11'.
 - 10-I:** Contains a large rectangular room, a smaller room labeled 'F12', 'F13', 'SA3', 'FA4', 'KA4', 'K4', and 'Z1'.
 - 10-J:** Contains a large rectangular room, a smaller room labeled 'F15', 'SA5', 'F16', 'SA6', 'F11', and a room labeled 'X3, X5, X6'.
- Orientation:** A vertical line labeled 'ÚROVEŇ TERÉNU' (Level of the terrain) is shown on the left side of the plan.