

# Tightness control TC 1, TC 2, TC 3

## OPERATING INSTRUCTIONS

Cert. Version 07.22 · Edition 03.25 · EN · 03251469



### 1 SAFETY

#### 1.1 Read the operating instructions before use



Please read through these instructions carefully before installing or operating. Following the installation, pass the instructions on to the operator. This unit must be installed and commissioned in accordance with the regulations and standards in force. These instructions can also be found at [www.docuthek.com](http://www.docuthek.com).

#### 1.2 Explanation of symbols

**1, 2, 3, a, b, c** = Action

→ = Instruction

#### 1.3 Liability

We will not be held liable for damage resulting from non-observance of the instructions and non-compliant use.

#### 1.4 Safety instructions

Information that is relevant for safety is indicated in the instructions as follows:



#### DANGER

Indicates potentially fatal situations.



#### WARNING

Indicates possible danger to life and limb.



#### CAUTION

Indicates possible material damage.

All interventions may only be carried out by qualified gas technicians. Electrical interventions may only be carried out by qualified electricians.

#### 1.5 Conversion, spare parts

All technical changes are prohibited. Only use OEM spare parts.

### CONTENTS

1 Safety	1
2 Checking the usage	2
3 Installation	3
4 Wiring	4
5 Tightness test	6
6 Setting the test instant	6
7 Setting the measurement time	6
8 Commissioning	8
9 Assistance in the event of malfunction	8
10 Maintenance	10
11 Technical data	10
12 Designed lifetime	10
13 Logistics	10
14 Certification	11
15 Disposal	12

## 2 CHECKING THE USAGE

Tightness control for checking two safety valves before and after burner run, with adjustable measurement time for adjustment to different test volumes, leakage rates and inlet pressures. The TC is used in industrial thermoprocessing equipment, on boilers and on forced draft burners.

### TC 1, TC 2

For gas solenoid valves, quick opening or slow opening with start gas rate.

### TC 3

With fitted auxiliary valves for quick or slow opening gas solenoid valves as well as for motorized valves. This function is only guaranteed when used within the specified limits – see page 10 (11 Technical data). Any other use is considered as non-compliant.

#### 2.1 Type code TC 1V

<b>TC</b>	Tightness control
<b>1V</b>	For attachment to valVario
<b>05</b>	$p_u$ max. 500 mbar
<b>W</b>	Mains voltage 230 V AC, 50/60 Hz
<b>Q</b>	Mains voltage 120 V AC, 50/60 Hz
<b>K</b>	Mains voltage 24 V DC
<b>/W</b>	Control voltage: 230 V AC, 50/60 Hz
<b>/Q</b>	Control voltage: 120 V AC, 50/60 Hz
<b>/K</b>	Control voltage: 24 V DC


#### 2.2 Type code TC 1C, TC 2, TC 3

<b>TC</b>	Tightness control
<b>1C</b>	For attachment to CG
<b>2</b>	For quick opening individual valves
<b>3</b>	For quick or slow opening individual valves
<b>R</b>	$R_p$ internal thread
<b>N</b>	NPT internal thread
<b>05</b>	$p_u$ max. 500 mbar
<b>W</b>	Mains voltage 230 V AC, 50/60 Hz
<b>Q</b>	Mains voltage 120 V AC, 50/60 Hz
<b>K</b>	Mains voltage 24 V DC
<b>/W</b>	Control voltage: 230 V AC, 50/60 Hz
<b>/Q</b>	Control voltage: 120 V AC, 50/60 Hz
<b>/K</b>	Control voltage: 24 V DC

TC..N only for 120 and 24 V


#### 2.3 Type label

Gas type, measurement time, installation position, mains voltage, mains frequency, power consumption, ambient temperature, enclosure, max. switch-on current and max. inlet pressure – see type label.




## 2.4 Part designations

### TC 1V




- 1 TC 1V
- 2 Connectors
- 3 5 x M16 cable glands
- 4 2 x O-rings

### TC 1C




- 1 TC 1C for combination controls CG
- 2 1 x adapter
- 2 x O-rings
- 2 x retaining screws
- 3 Connectors
- 4 5 x M16 cable glands
- 5 2 x O-rings

### TC 2



- 1 TC 2 for solenoid valves
- 2 1 x adapter
- 2 x O-rings
- 2 x retaining screws
- 3 Connectors
- 4 5 x M16 cable glands
- 5 2 x O-rings

### TC 3




- 1 TC 3
- 2 Auxiliary valves
- 3 Valve block
- 4 5 x M16 cable glands
- 5 1 x screw plug

## 3 INSTALLATION

### ⚠ CAUTION

Please observe the following to ensure that the unit is not damaged during installation:


- Dropping the device can cause permanent damage. In this event, replace the entire device and associated modules before use.
  - Avoid formation of condensation in the device.
  - Do not store or install the unit in the open air.
  - Check max. inlet pressure.
  - Use a suitable spanner. Do not use the device as a lever. Risk of external leakage.
- Installation in the vertical or horizontal position, housing cover/indicators must not point upwards or downwards. The electrical connection should preferably be pointing downwards or towards the outlet.



- The device must not be in contact with masonry. Minimum clearance 20 mm (0.78").
- Use the O-rings supplied.
- In the case of very large test volumes  $V_P$ , an installed relief line should be of nominal size 40 to allow for the discharge of the test volume  $V_P$ .


### 3.1 Mounting TC 1V to valVario controls

- 1 Disconnect the system from the electrical power supply.
- 2 Close the gas supply.




- The O-rings must be inserted in the connectors of the TC.
- The solenoid actuator cannot be rotated on solenoid valves with proof of closure switch VCx..S or VCx..G.
- Connect the TC to the inlet pressure connection  $p_u$  and the interspace pressure connection  $p_z$  of the inlet valve. Ensure that connections  $p_u$  and  $p_z$  on the TC and the gas solenoid valve are not reversed.
- TC and bypass/pilot gas valve cannot be fitted together on the same side of the double block valve.
- In the case of a VCx combination, it is recommended to always install the bypass/pilot gas valve on the rear of the second valve and the tightness control on the viewing side of the first valve, together with the connection box.

- The TC is secured using two captive, self-tapping combination Torx screws T20 (M4) inside the housing. Do not undo any other screws!




### VAS 1–3, VCx 1–3



- Tighten the screws with max. 250 Ncm.


### VAS 6–9, VCx 6–9




- Tighten the screws with max. 250 Ncm.

### 3.2 Mounting TC 1C to combination control CG

- 1 Disconnect the system from the electrical power supply.
- 2 Close the gas supply.




- The O-rings must be inserted in the connectors of the TC.
- Use the adapter plate supplied to mount the TC 1C to combination control CG.
- Connect the TC to the inlet pressure connection  $p_u$  and the interspace pressure connection  $p_z$  of the inlet valve. Ensure that connections  $p_u$  and  $p_z$  on the TC and the gas solenoid valve are not reversed.




- Tighten the screws with max. 250 Ncm.

### 3.3 Mounting TC 2


- 1 Disconnect the system from the electrical power supply.
- 2 Close the gas supply.




- The O-rings must be inserted in the connectors of the TC.
- Connect the TC to the inlet pressure connection  $p_u$  and the interspace pressure connection  $p_z$  of the inlet valve.
- Use the adapter plate supplied for installation.




- We recommend using Ermeto screw couplings to attach the adapter plate to the gas solenoid valve. It may be necessary to compensate the distance to the valve housing.




- Only use approved sealing material to seal the pipe connections.



- 9 Connect the interspace pressure connection  $p_z$  on the adapter plate to the space between the valves using a 12 x 1.5 or 8 x 1 pipe.




- Ensure that connections  $p_u$  and  $p_z$  on the TC and adapter plate are not reversed.




### 3.4 Mounting TC 3

- Connect the TC to the inlet pressure connection  $p_u$ , the interspace pressure connection  $p_z$  and the outlet pressure connection  $p_d$  of the inlet valve. Ensure that connections  $p_u$ ,  $p_z$  and  $p_d$  on the TC are not reversed.



- Use a 12 x 1.5 or 8 x 1 pipe for the pipe connections.



- 1 Mount TC 3.
- Only use approved sealing material to seal the pipe connections.
- 2 Seal the unused connection  $p_z$  on the TC using the sealing plug supplied.

## 4 WIRING



### WARNING

Risk of injury!

Please observe the following to ensure that no damage occurs:

- Electric shocks can be fatal! Before working on possible live components, ensure the unit is disconnected from the power supply.
- Incorrect wiring may result in unsafe states and the destruction of the tightness control, the automatic burner control unit or the valves.
- Do not reverse L1 (+) and N (-).
- Cable cross-sections must be designed for the current rating of the selected external fuse.
- The valve outputs on the automatic burner control unit connected to the TC must be safeguarded by an external slow-acting fuse of max. 5 A (e.g. in the automatic burner control unit).

- Wiring to EN 60204-1.
- Use connection terminals with a cable cross-section of max. 2.5 mm<sup>2</sup>.
- Conductors which have not been connected (spare conductors) must be insulated at their ends.
- Do not set the remote reset so that it operates (automatically) in cycles.
- The data on the type label must comply with the mains voltage.


→ Length of the connection cable, see page 10 (11 Technical data).

## ⚠ CAUTION

Please observe the following to ensure that the unit is not damaged during operation:

- Avoid voltage and current peaks! It is recommended to equip connected valves with a protective circuit in accordance with the manufacturer's instructions.
- 1** Disconnect the system from the electrical power supply.
  - 2** Close the gas supply.
- Before opening the unit, the fitter should ground himself.
- 3** Open the housing cover of the TC.

## Preparing the wiring




- 7** Secure used cable glands. Tightening torque: max. 3.5 Nm.
- Unused cable glands are to remain closed with a plug. Otherwise, dirt or moisture can penetrate the housing.

- 8** Wire as shown on the connection diagram.
- For PE wire connection, 5 PE terminals are available for forwarding. They are designed as distributor terminals, e.g. to connect the PE wires of the valves to the system PE (connection to the system PE must be carried out/wired by the user).

## Connection diagram for TC 1, TC 2


Mains voltage and control voltage:  
24 V DC/120 V AC/230 V AC




## Connection diagram for TC 3

- The tightness test is carried out with the auxiliary valves installed on the TC 3 (pre-wired). The terminals for the valve inputs remain vacant.

Mains voltage and control voltage:  
24 V DC/120 V AC/230 V AC



## Finishing the wiring




## 5 TIGHTNESS TEST

- All new connections between the valve and the TC must be checked for tightness.
- 1** Pressurize the system. Do not exceed the maximum inlet pressure.
- 2** Use a soap solution to check the pipe connections for leaks.

## 6 SETTING THE TEST INSTANT

- The test instant (MODE) can be set using two DIP switches.
- 1** Disconnect the unit from the electrical power supply.
- Before opening the unit, the fitter should ground himself.
- 2** Unscrew the housing cover.
- 3** Set the test instant to Mode 1, 2 or 3.
- Mode 1: test before burner start-up with incoming thermostat/start-up signal  $\overline{V_1}$  (factory setting).
- Mode 2: test after burner run when the thermostat/start-up signal  $\overline{V_1}$  drops and after switching on the mains voltage.
- The tightness test also starts after a reset.
- Mode 3: test with incoming thermostat/start-up signal  $\overline{V_1}$  before burner start-up and when the thermostat/start-up signal  $\overline{V_1}$  drops after burner run.




- Invalid switch setting: no function. The operating signal LED  $\odot$  is permanently red, see page 8 (9 Assistance in the event of malfunction).



- Continue with page 6 (7 Setting the measurement time).

## 7 SETTING THE MEASUREMENT TIME

- The measurement time  $t_M$  can be set with a jumper in increments of 5 s to max. 30 s.
- $t_M$  is set to 30 s at the factory.



- No jumper: no function. The operating signal LED  $\odot$  is permanently red, see page 8 (9 Assistance in the event of malfunction).
- The longer the measurement time  $t_M$ , the greater the sensitivity of the tightness control. The longer the measurement time, the lower the leakage rate at which a safety shut-down/fault lock-out is triggered.
- The tightness control TC requires a minimum start rate in order to carry out tightness tests on slow opening valves:  
up to 5 l (1.3 gal) test volume  $V_P = 5\%$  of maximum flow rate  $Q_{max.}$   
up to 12 l (3.12 gal) test volume  $V_P = 10\%$  of maximum flow rate  $Q_{max.}$

### 7.1 Determining the measurement time

If a leakage rate is specified, find the measurement time  $t_M$  from the following:

$Q_{max.}$  = max. flow rate [m<sup>3</sup>/h]

$Q_L = Q_{max.}$  [m<sup>3</sup>/h] x 0.1% = leakage rate [l/h]

$p_u$  = inlet pressure [mbar]


$V_P$  = test volume [l]

$$t_M [s] = \frac{2,5 \times p_u [\text{mbar}] \times V_P [l]}{Q_L [l/h]}$$

For all CG versions, measurement time  $t_M$  must be set to 5 s on TC 1C.

### 7.2 Determining the test volume

Test volume  $V_P$  is calculated from the valve volume  $V_V$ , added to the volume of the pipe  $V_R$  for each additional metre in length  $L$ .



Valves	Valve volume $V_V$ [l]	Nominal size DN	Pipe volume $V_R$ [l/m]
VG 10	0.01	10	0.1
VG 15	0.05	15	0.2
VG 20	0.10	20	0.3

Valves	Valve volume $V_V$ [l]	Nominal size DN	Pipe volume $V_R$ [l/m]
VG 25	0.11	25	0.5
VG 40/VK 40	0.64	40	1.3
VG 50/VK 50	1.61	50	2
VG 65/VK 65	2.86	65	3.3
VG 80/VK 80	4	80	5
VG 100/VK 100	8.3	100	7.9
VK 125	13.6	125	12.3
VK 150	20	150	17.7
VK 200	42	200	31.4
VK 250	66	250	49
VAS 125	0.08		
VAS 240	0.27		
VAS 350	0.53		
VAS 665	1.39		
VAS 780	1.98		
VAS 8100	3.32		
VAS 9125	5.39		
VCS 125	0.05		
VCS 240	0.18		
VCS 350	0.35		
VCS 665	1.15		
VCS 780	1.41		
VCS 8100	2.85		
VCS 9125	4.34		

### 7.3 Determining the leakage rate

If no leakage rate  $Q_L$  is specified, we recommend the max. possible test period/measurement time is set.

It is possible to check a specific leakage rate  $Q_L$  using the TC. Within the European Union, the maximum leakage rate  $Q_L$  is 0.1% of the maximum flow rate  $Q_{(n) \text{ max.}}$  [ $\text{m}^3/\text{h}$ ].

$$Q_L \text{ [l/h]} = \frac{Q_{(n) \text{ max.}} \text{ [m}^3/\text{h]} \times 1000}{1000}$$

If a low leakage rate  $Q_L$  is to be detected, a long test period/measurement time must be set.

### 7.4 Calculation of the measurement time

A web app for calculating the measurement time  $t_M$  is available at [www.adlatus.org](http://www.adlatus.org).

Calculation example:

$$Q_{\text{max.}} = 100 \text{ m}^3/\text{h}$$

$$p_u = 100 \text{ mbar}$$

$$V_P = V_V + L \times V_R = 7 \text{ l}$$

$$Q_L = (100 \text{ m}^3/\text{h} \times 1000)/1000 = 100,000 \text{ l/h} / 1000 = 100 \text{ l/h}$$

$$t_M \text{ [s]} = \frac{2,5 \times p_u \text{ [mbar]} \times V_P \text{ [l]}}{Q_L \text{ [l/h]}}$$

$$(2,5 \times 100 \times 7)/100 = 17,5 \text{ s}$$

Set the next highest value (in this example 20 s).



### 7.5 Setting the measurement time on the device

To set the calculated measurement time, the jumper in the device must be reconnected as described below.

- 1 Disconnect the system from the electrical power supply.
- 2 Unscrew the housing cover.
- 3 Set the jumper to the position for the required measurement time (calculation example = 20 s).
- 4 Position the housing cover and screw tight.
- 5 Mark the set measurement time  $t_M$  on the type label with a waterproof pen.



- 6 Switch on the power supply.

→ The operating signal LED  flashes yellow (0.2 s on/off). After 10 s, the TC accepts the new setting and the LED  is yellow or green, see table, page 8 (8.1 Indicators and operating controls).

### 7.6 Calculating the entire test period


The entire test period  $t_P$  is made up of the measurement times  $t_M$  of both valves and the fixed opening time  $t_L$  of both valves together.

$$t_P \text{ [s]} = 2 \times t_L + 2 \times t_M$$

The entire test period for this example is as follows:  
 $2 \times 3 \text{ s} + 2 \times 20 \text{ s} = 46 \text{ s}$ .

## 8 COMMISSIONING

### 8.1 Indicators and operating controls



LED	Meaning
Power	Power supply
	Operating signal
	Valve 1
	Valve 2
	Reset button

The LEDs can display messages using three colours (green, yellow, red) and permanent or flashing light .

LED	Message/Operating status
Power	Green Power supply OK
	Yellow TC is ready for operation; safety interlock* input signal interrupted
	Green TC is ready for operation; active safety interlock* input signal
	Green V1 is tight
	Yellow V1 is untested
	Yellow Tightness test is running on V1
	Red V1 is leaking
	Green V2 is tight
	Yellow V2 is untested
	Yellow Tightness test is running on V2
	Red V2 is leaking
All	Yellow Initialization

\* Safety interlock = linking of all the relevant safety-related control and switching equipment for the use of the application. The burner start enable signal is issued via the safety interlock output (terminal 6).

→ For other messages, see TC 1–3 operating instructions, page 8 (9 Assistance in the event of malfunction).

### 8.2 Switching on the mains voltage

→ All the LEDs will be lit in yellow for 1 s when the mains voltage has been switched on. The TC is in the initialization phase.

→ The test starts according to the test instant (Mode) which has been set.

### 8.3 During the test

Mode 1 or Mode 3, test before burner start-up: Voltage at terminal 10 (thermostat/start-up signal ).

Or

Mode 2, test after burner run:

The TC shows the last operating status. In the case of untested valves, the and LEDs are yellow. There is mains voltage at terminal 1 and renewed test after switching off the voltage to terminal 10 (thermostat/start-up signal ).

→ During the test, the and LEDs will flash yellow.

### 8.4 After the test

The and LEDs are green:

Both valves are tight.

Mode 1 or Mode 3: the enable signal is issued via terminal 6 when voltage is applied to terminal 5.

Or

Mode 2: the enable signal is issued via terminal 6 when voltage is applied to terminals 10 and 5.

The or LED is red:

A valve is leaking.

Voltage at terminal 12. A fault signal is output.

### 8.5 Power failure

If the power fails briefly during the test or during operation, the tightness test will restart in accordance with the test procedure described.

If there is a fault message, the fault is displayed again after a power failure.

## 9 ASSISTANCE IN THE EVENT OF MALFUNCTION



### DANGER

Electric shocks can be fatal!

- Before working on possible live components, ensure the unit is disconnected from the power supply.



### WARNING

To avoid harm to persons and damage to the unit, please observe the following:

- Fault-clearance must only be undertaken by authorized trained personnel.
- (Remote) resets may only be conducted by authorized trained personnel.

→ Faults may be cleared only using the measures described below.

→ Press the reset button to test whether the TC restarts.

→ If the tightness control will not start even though all faults have been remedied, remove the entire TC (in the case of TC 3, including auxiliary valves



and corresponding valve block) and send it to the manufacturer for inspection.

## Fault

- ! Cause
  - Remedy

### 9.1 Power LED is permanently red.

- ! There is over-/undervoltage. The TC performs a safety shut-down.
  - Check the mains voltage. As soon as there is no longer over-/undervoltage, the TC returns to normal operating mode and the Power LED is green. It is not necessary to reset the device.

### 9.2 Operating signal LED is permanently yellow.

- ! Safety interlock input signal is interrupted, no voltage at terminal 5. The tightness test is still being carried out. No enable signal is issued to the automatic burner control unit.
  - Check safety interlocks.

- ! Fuse F2 defective.
  - Replace F2, see page 9 (9.8.1 Replacing the fuse).

### 9.3 LED flashes yellow.

- ! Permanent remote reset. The remote reset signal has been active for more than 10 s.
  - The warning signal is cancelled once the remote reset signal to terminal 11 has been removed.

### 9.4 Operating signal LED is permanently red.

- ! Incorrect jumper/DIP switch setting.
  - Correct jumper and DIP switch setting, see page 6 (7 Setting the measurement time) and page 6 (6 Setting the test instant). Then press the reset button.
- ! Internal error.
  - Remove the unit and return it to the manufacturer for inspection.

### 9.5 Operating signal LED flashes red.

- ! Too frequent burner start commands. The TC performs a fault lock-out. The start commands are limited to 5 x in 15 minutes.
  - As long as this limit is not exceeded, another start-up attempt is possible after three further minutes. If a tightness test is completed, the counter which limits the number of start commands is reset.
    - Then press the reset button.
- ! Too many remote resets. More than 5 resets have been conducted within the last 15 minutes, either automatically or manually.
- ! Consecutive fault caused by a previous fault whose actual cause has not been remedied.
  - Pay attention to previous fault messages.

- Remedy cause. Then press the reset button.

### 9.6 1 or 2 LED is permanently red.

- ! The valve is leaking. The TC performs a fault lock-out.
  - Replace the valve.
- ! Wiring of the TC to the valves is faulty.
  - Start the program and observe the interspace pressure  $p_z$ . The pressure must change during the TEST phase. Check the wiring.
- ! Inlet pressure  $p_U < 10$  mbar.
  - Provide the min. inlet pressure of 10 mbar.
- ! Interspace pressure  $p_z$  cannot be reduced.
- ! The volume downstream of the valve on the burner side must be 5 times higher than the volume between the valves and atmospheric pressure must prevail.
- ! The measurement time  $t_M$  is too long.
  - Adjust  $t_M$ , see page 6 (7 Setting the measurement time).

### 9.7 1 and 2 LEDs are permanently red.


- ! During the tightness test, the TC has determined that inlet valve 1 and outlet valve 2 have been reversed (fault lock-out).
  - Check the wiring. Then press the reset button.

### 9.8 No LED lit even though mains voltage applied.

- ! Fuse F1 defective.
  - Replace F1, see page 9 (9.8.1 Replacing the fuse).

#### 9.8.1 Replacing the fuse

- The fuses F1 and F2 can be removed for inspection.
- Insert a screwdriver into the opening in the contact guard to prise out the fuse.



- 1 Disconnect the TC from the electrical power supply.
- Before opening the unit, the fitter should ground himself.
- 2 Unscrew the housing cover.
- 3 Remove fuse F1 or F2.
- 4 Check function of fuse.
- 5 Replace the fuse if defective.
- When replacing the fuse, use only the approved fuse type, see page 10 (11.3 Electrical data).
- Restart the TC, see page 8 (8 Commissioning).

10 MAINTENANCE

TC 1, TC 2, TC 3 requires little servicing.  
We recommend that a function check is carried out once per year, or at least twice a year if biogas is used.

11 TECHNICAL DATA

11.1 Ambient conditions

Icing, condensation and dew in and on the unit are not permitted.  
Avoid direct sunlight or radiation from red-hot surfaces on the unit. Note the maximum medium and ambient temperatures!  
Avoid corrosive influences, e.g. salty ambient air or SO<sub>2</sub>.  
The unit may only be stored/installed in enclosed rooms/buildings.  
The unit is suitable for a maximum installation height of 2000 m AMSL.  
Ambient temperature: -20 to +60°C (-4 to +140°F), no condensation permitted.  
Long-term use in the upper ambient temperature range accelerates the ageing of the elastomer materials and reduces the service life (please contact manufacturer).  
Storage temperature = transport temperature: -20 to +40°C (-4 to +104°F).  
Enclosure: IP 65.  
This unit is not suitable for cleaning with a high-pressure cleaner and/or cleaning products.

11.2 Mechanical data

Gas types: natural gas, LPG (gaseous), biogas (max. 0.1 %-by-vol. H<sub>2</sub>S) or clean air. The gas must be clean and dry in all temperature conditions and must not contain condensate.  
Medium temperature = ambient temperature.  
Inlet pressure p<sub>0</sub>: 10 to 500 mbar (3.9 to 195 "WC).  
Measurement time t<sub>M</sub>: 5 to 30 s, adjustable. Set at the factory to 30 s.  
Valve opening time: 3 s.  
Housing made of impact-resistant plastic.  
Connectors: aluminium.  
Weight:  
TC 1V: 215 g (0.47 lbs),  
TC 2 with adapter: 260 g (0.57 lbs),  
TC 3: 420 g (0.92 lbs).

11.3 Electrical data

Mains voltage and control voltage:  
120 V AC, -15/+10%, 50/60 Hz,  
230 V AC, -15/+10%, 50/60 Hz,  
24 V DC, ±20%.  
Power consumption (all LEDs green):  
5.5 W at 120 V AC and 230 V AC,  
2 W at 24 V DC,  
TC 3: plus 8 VA for an auxiliary valve.  
Fine-wire fuse:  
5 A, slow-acting, H, 250 V, pursuant to IEC 60127-

2/5,  
F1: protection of valve outputs (terminals 15 and 16), fault signal (terminal 12) and supply of the control inputs (terminals 2, 7 and 8).  
F2: protection of safety interlock/controller enable signal (terminal 6).  
The input current at terminal 1 must not exceed 5 A.  
Max. load current (terminal 6) for safety interlock/controller enable and valve outputs (terminals 15 and 16):  
at 230/120 V AC mains voltage, max. 3 A resistive load;  
at 24 V DC mains voltage, max. 5 A resistive load.  
Fault signal (terminal 12):  
Fault output at 120 V AC/230 V AC/24 V DC mains and control voltage:  
max. 5 A.  
TC switching cycles:  
250,000 pursuant to EN 13611.  
Reset: using a button on the device or by remote reset.  
Length of connection cable:  
at 230 V AC/120 V AC: any, at 24 V DC (supply connected to PE): max. 10 m permitted,  
at 24 V DC (supply not connected to PE): any.  
5 cable glands:  
M16 x 1.5.  
Electrical connection:  
Cable cross-section: min. 0.75 mm<sup>2</sup> (AWG 19), max. 2.5 mm<sup>2</sup> (AWG 14).

12 DESIGNED LIFETIME

This information on the designed lifetime is based on using the product in accordance with these operating instructions. Once the designed lifetime has been reached, safety-relevant products must be replaced.  
Designed lifetime (based on date of manufacture) in accordance with EN 13611 for TC 1, TC 2, TC 3:

Switching cycles	Time (years)
250,000	10

You can find further explanations in the applicable rules and regulations and on the afecor website ([www.afecor.org](http://www.afecor.org)).  
This procedure applies to heating systems. For thermoprocessing equipment, observe local regulations.

13 LOGISTICS

Transport

Protect the unit from external forces (blows, shocks, vibration).  
Transport temperature: see page 10 (11 Technical data).  
Transport is subject to the ambient conditions described.  
Report any transport damage on the unit or packaging without delay.

Check that the delivery is complete.

**Storage**

Storage temperature: see page 10 (11 Technical data).

Storage is subject to the ambient conditions described.

Storage time: 6 months in the original packaging before using for the first time. If stored for longer than this, the overall service life will be reduced by the corresponding amount of extra storage time.

**14 CERTIFICATION**

**14.1 Certificate download**

Certificates – see [www.docuthek.com](http://www.docuthek.com)

**14.2 Declaration of conformity**



We, the manufacturer, hereby declare that the product TC 1–3 with product ID No. CE-0063DN1848 complies with the requirements of the listed Directives and Standards.

Directives:

- 2014/35/EU – LVD
- 2014/30/EU – EMC
- 2011/65/EU – RoHS II
- 2015/863/EU – RoHS III

Regulation:

- (EU) 2016/426 – GAR

Standards:

- EN 1643:2014
- EN 60730-2-5:2015
- EN 61508:2010, Parts 1–7
- SIL 3 according to EN 61508

The relevant product corresponds to the tested type sample.

The production is subject to the surveillance procedure pursuant to Regulation (EU) 2016/426 Annex III paragraph 3.

Elster GmbH

**14.3 SIL**



Safety-specific characteristic values, see Safety manual/Technical Information TC (D, GB, F) –[www.docuthek.com](http://www.docuthek.com).

**14.3.1 Safety-specific characteristic values for SIL**

Mains and control voltage: 120 V AC/230 V AC	
Diagnostic coverage DC	91.4%
Mean probability of dangerous failure PFH <sub>D</sub>	17.3 x 10 <sup>-9</sup> 1/h

Mains and control voltage: 24 V DC	
Diagnostic coverage DC	91.5%
Mean probability of dangerous failure PFH <sub>D</sub>	17.5 x 10 <sup>-9</sup> 1/h

General	
Mean probability of dangerous failure PFH <sub>D</sub>	Auxiliary valves with valve block on TC 3: 0.2 x 10 <sup>-9</sup> 1/h
Type of subsystem	Type B to EN 61508-2
Mode of operation	High demand mode pursuant to EN 61508-4 Continuous operation (to EN 1643)
Mean time to dangerous failure MTTF <sub>d</sub>	1/PFH <sub>D</sub>
Safe failure fraction SFF	97.5%

For a glossary of terms, see [Technical Information TC, Glossary](#).

**14.4 AGA approved**



Australian Gas Association, Approval No.: 8618.

**14.5 Eurasian Customs Union**



The products TC 1, TC 2, TC 3 meet the technical specifications of the Eurasian Customs Union.

**14.6 REACH Regulation**

The device contains substances of very high concern which are listed in the Candidate List of the European REACH Regulation No. 1907/2006. See Reach list HTS at [www.docuthek.com](http://www.docuthek.com).

**14.7 China RoHS**

Directive on the restriction of the use of hazardous substances (RoHS) in China. Scan of the Disclosure Table China RoHS2, see certificates at [www.docuthek.com](http://www.docuthek.com).

## 15 DISPOSAL

Devices with electronic components:

### **WEEE Directive 2012/19/EU – Waste Electrical and Electronic Equipment Directive**



At the end of the product life (number of operating cycles reached), dispose of the packaging and product in a corresponding recycling centre. Do not dispose of the unit with the usual domestic refuse. Do not burn the product.

On request, old units may be returned carriage paid to the manufacturer in accordance with the relevant waste legislation requirements.

## FOR MORE INFORMATION

The Honeywell Thermal Solutions family of products includes Honeywell Combustion Safety, Eclipse, Exothermics, Hauck, Kromschöder and Maxon. To learn more about our products, visit [ThermalSolutions.honeywell.com](http://ThermalSolutions.honeywell.com) or contact your Honeywell Sales Engineer.

Elster GmbH  
Strotheweg 1, D-49504 Lotte  
T +49 541 1214-0  
[hts.lotte@honeywell.com](mailto:hts.lotte@honeywell.com)  
[www.kromschroeder.com](http://www.kromschroeder.com)

Global centralized service deployment coordination:  
T +49 541 1214-365 or -555  
[hts.service.germany@honeywell.com](mailto:hts.service.germany@honeywell.com)

Translation from the German  
© 2025 Elster GmbH

**Honeywell**  
**kromschöder**