



#	QTY Active	QTY Spare	QTY Comis	Description TAG	Model No. Comment	PLU	Size NO/NC	Manufacturer Parameter 1	-- Parameter 2	Supplied by Parameter 3	EX	SA FE	SI L	PL	MT TF	Note	A I	A O	D I	D O
2201	1	0	0	BALL VALVE	01305.2000.0001	702422+	50	HEROSE		HTT		0	-	-			0	0	0	0
				2-BV-1000			LO	Kvs = 37,1 m3/h	LOTO			F								
2202	1	0	0	STRAINER	08413.2000.7505	708034	50	HEROSE		HTT		0	-	-			0	0	0	0
				2-ST-1000			NO	Kvs = 28 m3/h				F								
2203	1	1	0	DIFFERENTIAL PRESSURE	PMD55B-AABACBA37FJGSAJA7B+H	706030		ENDRESS+HAUSER		HTT		1	-	-			1	0	0	0
				2-PD-1000				0...500 mbar	delta p			1				OX FILTER PRESSURE DROP	1			
2204	2	0	0	PRESSURE INDICATOR		N/A				N/A		0	-	-			0	0	0	0
				2-PI-1001								F								
				2-PI-1002								F								
2205	1	0	0	PRESSURE REGULATOR	757LE - 2", OF	706363	50	WITT		HTT		0	-	-			0	0	0	0
				2-PR-1000			NO	Kv = 15 m3/h	S.P.=4,5 bar(g)			F								
2206	2	1	0	PRESSURE SWITCH	DWR16 + ZF1979	706201		FEMA		HTT		0	-	-			0	0	2	0
				2-PS-1000				S.P.=??				F							1	
				2-PS-1001								F							1	
2207	1	1	0	FLOW METER	7F2C50-AADCCAACAAAD2SKA1+H	705051		ENDRESS+HAUSER		HTT		0	-	-			1	0	0	0
				2-FT-1000				Range = 0....1000 Nm/h // 4-20 mA	D.P = 150...1000 Nm3/h min.			F				1				
2208	1	0	0	TEMPERATURE TRANSMITTER	see 2-FT-1000	N/A		ENDRESS+HAUSER		N/A		0	-	-			1	0	0	0
				2-TT-1000								F					1			
2209	2	2	0	PRESSURE TRANSMITTER	PMC21-AA1U1QBWBJA+HBJA	706020		ENDRESS+HAUSER		HTT		0	-	-			2	0	0	0
				2-PT-1000				0...16 bar				F					1			
				2-PT-1001				0...16 bar				F					1			
2210	1	1	0	CONTROL VALVE	2000-A-2-50,0-EE-RG-GM89-B-E*MC	701043		BURKERT		HTT		0	-	-			0	0	0	0
				2-CV-1002				Kv = 49 m3/h				F								
2211	1	0	0	POSITIONER		675108		BURKERT		N/A		0	-	-			1	1	0	0
				2-PO-1000								F					1	1		
2212	1	1	0	BALL VALVE	DA63M-AB2BBB+E1E9	702006	4	ENDRESS+HAUSER		HTT		0	-	-			0	0	0	0
				2-BV-1003			NO													
2213	1	1	0	PILOT VALVE	6012-C01,2FBPA0000-2-024/DC-04*	701028+		BURKERT		HTT		0	-	-			0	0	0	1
				2-XV-1002			NC					F								1
2214	1	1	0	FLOW CONTROL VALVE	8802-GD-I-A-50,0EE-VA-GM89-P-0-E	701836		BURKERT		HTT		0	-	-			0	1	0	0
				2-FC-1000				Kv = 37 m3/h	Leak rate class: VI			F					1			
2215	1	0	0	BALL VALVE	S.198-1/2"	700051	8	ENOLGAS		HTT		0	-	-			0	0	0	0
				2-BV-4000			NO					F								
2216	1	0	0	LIMIT SWITCH BOX	8697-00-M2-FA05-0-Y-KD-00-0-0-0-0*	675104		BURKERT		HTT		0	-	-			0	0	2	0
				2-ZS-1002								F							2	
2217	1	0	0	FILTER REGULATOR	P32EB14ESMBNNP + P32KA00ML	708123+	6	PARKER		HTT		0	-	-			0	0	0	0
				2-FR-4001			NO	S.P.=6 bar(g)				F								
2218	1	1	0	PRESSURE SWITCH	DWR6	706202		FEMA		HTT		0	-	-			0	0	1	0
				2-PS-4000				S.P.=??				F							1	
2220	1	0	0	BALL VALVE	E4280005	701946	6	EUROFIT		HTT		0	-	-			0	0	0	0
				2-BV-4001			NO					F								
2221	1	0	0	PRESSURE TRANSMITTER	PMC21-AA1U1PBWBJA	706040		ENDRESS+HAUSER		HTT		0	-	-			1	0	0	0
				2-PT-4000								F					1			
2230	1	0	0	PRESSURE INDICATOR	358G G1/4", 0-10, Z	706143		THERMIS		HTT		0	-	-			0	0	0	0
				2-PI-4000								F								
2250	1	0	0	ENCLOSED CABINET	24092-B-004-60 / 8005199 / MODCZ	300997		RITTAL		HTT		0	-	-			0	0	0	0
				2-DE-1000				2000(+100)x1000x400				F								

#	QTY Active	QTY Spare	QTY Comis	Description TAG	Model No. Comment	PLU	Size NO/NC	Manufacturer Parameter 1	-- Parameter 2	Supplied by Parameter 3	EX	SA FE	SI L	PL	MT TF	Note	A I	A O	D I	D O
2251	1	0	0	MANIFOLD	3311 13 17 06	669101		LEGRIS		HTT		0	-	-			0	0	0	0
				2-DE-4000								F								
											EX	SAFE					AI	AO	DI	DO
												1	I / O SUMMARY				7	2	5	1