



Luminaire list (Building 1, Storey 1)							
Index	Manufacturer	Article name	Item number	FRPq	Luminaire flux	Maintenance factor	Connected load
1	TREX	EAHM FL1 (Lx150x30) L225 01 (R20)		1x 1xLED-ETED	14700 lm	0.70	87 W

#	Name	Parameter	Min	Max	Average	Min/Average	Max/Average
1	Calculation surface 1	Perpendicular Illuminance	405 lx	603 lx	605 lx	0.67	0.82
2	Calculation surface 2	Perpendicular Illuminance	462 lx	607 lx	605 lx	0.80	0.80
3	Calculation surface 3	Perpendicular Illuminance	477 lx	600 lx	607 lx	0.79	0.80
4	Calculation surface 4	Perpendicular Illuminance	581 lx	604 lx	594 lx	0.71	0.88
5	Calculation surface 5	Perpendicular Illuminance	581 lx	600 lx	592 lx	0.71	0.81
6	Calculation surface 6	Perpendicular Illuminance	596 lx	618 lx	599 lx	0.71	0.84
7	Calculation surface 7	Perpendicular Illuminance	587 lx	618 lx	599 lx	0.71	0.84
8	Calculation surface 8	Perpendicular Illuminance	596 lx	594 lx	592 lx	0.72	0.87
9	Workplane (from 1)	Perpendicular Illuminance (Actual)	503 lx	600 lx	606 lx	0.87	0.76