

Zak.č.:	6122					
Stavba:	Oddelenie rádiológie, Nemocnica Poprad a.s. - RTG 0.35 - Výmena strojného zariadenia Artis ZEE Multipurpose Sien					
Objekt:	Elektroinštalácia					
ZOZNAM KÁBLOV						
Položka	Označenie	Typ kábla	Adresa 1	Adresa 2	dĺžka n	Poznámka
1	035A-WE 00	H07Z-K 25zž	RH	HRT	70	
2	035-WE 00	H07Z-K 25zž	HRT	SC1	12	
3	035-WE 01	H07Z-K 25zž	HRT	UPS	12	
4	035-WE 02	H07Z-K 25zž	HRT	PU1	12	
5						
6	035-WL 00	N2XH-J5x70	RH	HRT	70	
7	035-WL 01	N2XH-J5x16	HRT	SC1	12	
8	035-WL 02	N2XH-J5x25	HRT	PU1	12	
9	035-WS 03	N2XH-J5x1,5	HRT	signalizácia "nevstupovať, žiarenie"	0	EXISTUJÚCI
10	035-WL 04	N2XH-J3x1,5	HRT	-SU	10	
11	035-WL IN	H07RN-F 5G16	HRT	UPS	14	
12	035-WL BP	H07RN-F 5G16	HRT	UPS	14	
13	035-WL OUT	H07RN-F 5G16	UPS	HRT	14	
14						
15	035-WS 1		HRT	AT1	0	EXISTUJÚCI
16	035-WS 2		HRT	AT2	0	EXISTUJÚCI
17	035-WS 3		HRT	AT3	0	EXISTUJÚCI
18	035-WS 4	rezerva				
19	035-WS 5	rezerva				
20	035-WS 6	rezerva				
21	035-WS 7	rezerva				
22	035-WS 8	rezerva				
23	035-WS 9	N2XH-O 2x1,5	HRT	UPS REPO	14	
24	035-WS 10	N2XH-J7x1,5	HRT	PU1	12	
25	035-WS SU	N2XH-O 3x1,5	HRT	ovládanie -S SU	15	
26						
27						
28	B03WL204	N2XH-J3x2,5	RB03	zásuvky IT	0	EXISTUJÚCI
29	B03WE204	H07Z-K 6zž	RB03	krabica pre zásuvky IT- svorka PE	18	
30	B03WS204	JE-H(St)H 4x2x0,8	RB03	SZIS4	25	
31	B03WL311	N2XH-J3x1,5	RB03	svetlo DO vyšetrovňa	16	
32	B03WL506	N2XH-J3x1,5	RB03	svetlo vyšetrovňa	18	
33						
34						
35						
36						
37						
38						
39						
40						
41						
42						
43						
44						
45						
46						
47						
48						
49						
50						
51						
52						
53						
54						
55						
56						
57						
58						
59						
60						