

#	QTY Active	QTY Spare	QTY Comis	Description TAG	Model No. Comment	PLU	Size NO/NC	Manufacturer Parameter 1	-- Parameter 2	Supplied by Parameter 3	EX	SA FE	SI L	PL	MT TF	Note	A I	A O	D I	D O
2301	3	0	0	GAUGE VALVE	ČSN 137517.A.5 G1/2" 42 3223 OF	701611	6	THERMIS		HTT		0	-	-			0	0	0	0
				3-GV-1000			NO													
				3-GV-1100			NO													
				3-GV-1200			NO													
2302	2	0	0	PRESSURE INDICATOR	384 G1/2" ,0-25, S, OF	706166		THERMIS		HTT		0	-	-			0	0	0	0
				3-PI-1100								F								
				3-PI-1200								F								
2303	1	0	0	PRESSURE TRANSMITTER	PMC21-AA1U1QBWBJA+HBJA	706020		ENDRESS+HAUSER		HTT		0	-	-			1	0	0	0
				3-PT-1000				0...16 bar				F					1			
2304	1	1	0	CONTROL VALVE	8801-GC-K-A-65,0EE-VA-FD28-P-0-E	702518		BURKERT		HTT		0	-	-			0	0	0	0
				3-CV-1000				Kv = 49 m3/h				F								
2305	1	0	0	PILOT VALVE	6012-C01,2FBPA0000-2-024/DC-04*	701028+		BURKERT		HTT		0	-	-			0	0	0	1
				3-XV-5000			NC					F								1
2306	1	0	0	CUSTOMER MANIFOLD CA 6 bar		669101				CUST		0	-	-			0	0	0	0
				3-DE-5000								F								
2307	2	1	0	CONTINUOUSLY OPERATED VALVE	01305.2000.XXXX	702430	50	HEROSE		HTT		0	-	-			0	0	0	0
				3-FC-1100			NO	Kvs = 30 m3/h				F								
				3-FC-1200			NO	Kvs = 30 m3/h				F								
2308	2	1	0	CHECK VALVE	NV400 G 2" RH	701401	50	WITTT		HTT		0	-	-			0	0	0	0
				3-CHV-1100			NO					F								
				3-CHV-1200			NO					F								
2309	2	1	0	HOSE	NEOS40, DN50 L=1000	610172	50	VINILGOMMA		HTT		0	-	-			0	0	0	0
				3-HS-1100			NO	L=1000				F								
				3-HS-1200			NO	L=1000				F								
2310	2	0	0	LANCE						CUST		0	-	-			0	0	0	0
				3-B-1100				500 Nm3/h	0,32 bar(g)			F								
				3-B-1200				500 Nm3/h	0,32 bar(g)			F								
2312	2	1	0	HOSE	NEOS40, DN25 L= 1000	610173	25	VINILGOMMA		HTT		0	-	-			0	0	0	0
				3-HS-5100			NO	L = 1000				F								
				3-HS-5200			NO	L = 1000				F								
2313	2	1	0	CHECK VALVE	NV300 G1"	701931	25	WITT		HTT		0	-	-			0	0	0	0
				3-CHV-5100			NO					F								
				3-CHV-5200			NO					F								
2314	1	0	0	CONTROL VALVE	2000-A-2-50,0-EE-RG-GM89-B-E*MC	701043		BURKERT		HTT		0	-	-			0	0	0	0
				3-CV-5000				Kv = 49 m3/h				F								
2315	1	0	0	HOSE			65			INSERTEC		0	-	-			0	0	0	0
				3-HS-1000			NO	L=1000				F								
2316	1	0	0	LIMIT SWITCH & PILOT BOX		675102				N/A		0	-	-			0	0	2	1
				3-XYP-1000								F							2	1
											EX	SAFE					AI	AO	DI	DO
												0					1	0	2	2

I / O SUMMARY