

The drawing shows a rectangular floor plan with overall dimensions of 5020 mm by 2720 mm. The plan includes several internal walls and columns, numbered 1 through 6. Key dimensions include:

- Overall Dimensions:** 5020 mm (width) x 2720 mm (depth).
- Internal Width Segments:** 1259 mm, 3700 mm, 2441 mm, and 1320 mm.
- Internal Depth Segments:** 80 mm, 1200 mm, 80 mm, 1200 mm, 80 mm, and 50 mm.
- Column Spacing:** 1200 mm between columns 1 and 2, 2121 mm between columns 2 and 3, and 2142 mm between columns 3 and 4.
- Room Dimensions:** A room at the top right has dimensions 1539 mm by 1539 mm.
- Other Dimensions:** 56 mm, 900 mm, 214 mm, and 80 mm are also indicated.

[illegible]

M1:15

POLOŽKA 3
KOTEVNÁ PLATŇA
os DIERA Ø14
2x CHEM. KOTVA HILTI
HIT-HY200-A V3+HAS-U 5.8 M12
HLBKA DIERY 100mm, Ø14

10 140 120 10 10 70 60 14 10 40 40 3

Technical drawing of a stepped shaft with dimensions: 5, 178, 152, 13, 74, 1.

80 190
100 40
266
8
1KS
PL.8/50-100
1KS
L100x50/8-266
8 6 100 30 32 43 25 7 14 25
os DIERA ø14

[illegible]

Technical drawing of a rectangular plate. Dimensions are given in millimeters. The plate has a width of 80 mm and a height of 200 mm. There are two vertical slots, each 47 mm wide and 33 mm deep. The distance between the inner faces of the slots is 60 mm. The distance from the left edge to the first slot is 18 mm. The distance from the right edge to the second slot is 12 mm. The distance from the top edge to the first slot is 98 mm. The distance from the bottom edge to the second slot is 42 mm. The plate is labeled with '13' and '12' at the top corners. The text 'DIERA Ø18' is written vertically on the left side.

[illegible]

M 1:25

M 1:25

J 5.8 M16
M18

Dimensions:
69, 112, 59, 108, 17, 15, 13

[illegible]

Technical drawing of a roof structure showing a cross-section of a roof with a 12% slope. The drawing includes dimensions for the roof width (1200), height (1176), and various components like the roof plate (PL.12/80-200), roof edge (UPE 200-1176), and roof supports (1KS). A dimension of 21 is also indicated.

[illegible]

OZN.	POPIS	kg/m kg/m ²	DLŽINA (m) PLOŠČA(m ²)	HMOTNOST kg /kus	POČET KUSOV	HMOTNOST SPOLU (kg)	OCEL	POZNÁMKA
02N.	UFPE 200	22,80	5,466	124,62	1	124,62	S235	
2	UPE 120	12,10	0,071	0,86	2	1,72	S235	
3	PL.8/70-140	4,40	0,140	0,62	4	2,48	S235	
4	L40/8	2,97	1,160	3,44	2	6,88	S235	
5	PL.8/74-178	4,65	0,178	0,83	8	6,62	S235	
6	L100x50/8	8,97	0,266	2,39	2	4,77	S235	
7	PL.8/50-100	3,14	0,100	0,314	2	0,628	S235	
8	PL.8/70-190	4,40	0,190	0,836	2	1,67	S235	
9	L40/8	2,97	0,410	1,22	1	1,22	S235	
10	L40/8	2,97	0,910	2,70	1	2,70	S235	
11	L40/8	2,97	0,125	0,37	1	0,37	S235	
12	UPE 200	22,80	5,785	131,90	1	131,90	S235	
13	PL.12/80-200	7,54	0,200	1,51	2	3,02	S235	
14	L40/8	2,97	1,550	4,60	1	4,60	S235	
15	UFPE 200	22,80	4,073	92,64	1	92,64	S235	
16	L40/8	2,97	1,180	3,50	2	7,00	S235	
17	PL.8/100-116	6,28	0,116	0,73	1	0,73	S235	
18	PL.12/240-108	22,64	0,108	2,45	2	4,89	S235	
19	UPE 200	22,80	4,165	94,96	1	94,96	S235	
20	UPE 200	22,80	1,176	26,81	1	26,81	S235	
21	PL.12/80-200	7,54	0,200	1,51	4	6,03	S235	
22	UPE 200	22,80	2,536	57,82	1	57,82	S235	
23	UPE 120	12,10	2,583	31,25	2	62,51	S235	
24	PL.8/96-96	6,03	0,096	0,58	4	2,32	S235	
25	PL.6/30-48	1,41	0,048	0,07	8	0,54	S235	
26	PL.12/60-120	5,65	0,120	0,68	2	1,36	S235	
27N.	KRÍŽOVÉ ZAVETRENIE HALFEN BETAN-S FV						-	
HMOTNOST SPOLU (kg)						651,10		
ZVARY 2X (kg)						13,00		
HMOTNOST SPOLU=						664,1 kg		

-  - ZLOM V DOLNEJ HRANE DOSKY
-  - ZLOM V HORNEJ HRANE DOSKY
-  - ŽELEZOBETÓN V REZE
-  - ŽELEZOBETÓNOVÉ KONŠTRUKCIE NAD DOSKOU
-  - PRACOVNÁ ŠKÁRA

- TÁTO DOKUMENTÁCIA SLUŽÍ AKO PODKLAD PRE DIELENSKÚ DOKUMENTÁCIU. VÝROBA OCEĽ. KONŠTRUKCIE AŽ PO ZAMERANÍ SKUTKOVÉHO STAVU.
- BEZPEČNOSTNÉ ŽÁBRADLIE BUDE PRICHYTENÉ NA HORNÚ PÁSNICU UPE 200. PRE POLOHY STÍPKOV VÍD ČASŤ ARCHITEKTÚRA.
- POD ZÁKLADOVÉ KONŠTRUKCIE NEREALIZOVAŤ ŠTRKOVÝ PODSPY ! POUŽÍŤ PODKLADNÉ BETÓN.
- ZÁKLAD REALIZOVAŤ VŽDY DO VÝKOPU RASTLEHO TERÉNU, NIKDY NIE NA NÁSPYE !
- VIDITEĽNÉ HRANY ŽB KONŠTRUKCIÍ KOŠÍŠ 10/10

OCEL' : S235JR+N

POVRCHOVÁ ÚPRAVA : METALIZÁCIA ŽIAROVÝM ZINKOVANÍM V HRÚBKE 100 µm

BETÓN :

ZÁKLADY : C25/30 XC2 (SK) - Cl 0.4 - Dmax 22 - S3

STENY : C30/37 XC4,XF1 (SK) - Cl 0.4 - Dmax16 - S4

KRYTIE : DOSKA,ZAKL.PÁS 50mm ,STENY 40mm

PODKLADNÝ BETÓN : C12/15 XC0

BETONÁRSKA VÝSTUŽ : B500 B

$\pm 0,000 = 222,950 =$ PRÍZEMIE JESTVUJÚCEHO OBJEKTU - ŠKOLY

AUTOR	statika MM s.r.o., Ing. Marek Baláž					 statika MM s.r.o. Bratislava, P.O. Box 67 Bratislava, Slovakia www.statikaonline.sk			
HIP.	Ing. arch. BRANISLAV BANÍK Pn križ 12, 84102, Bratislava								
VYPRACOVAL	Ing. Marek Baláž								
NÁZOV STAVBY	ZAKLADNÁ ŠKOLA LAMČ, MALOKARPATSKÉ NÁMESTIE 1					Malokarpatské námestie 1 Lamča, 841 03 Bratislava			
NÁZOV VÝKR.	Oceľové schodisko					Miestnosť čast' Bratislava Lamča Malokarpatské námestie 9, 841 03 Bratislava			
DÁTUM	JANUÁR 2026		FORMÁT 420x1050		MERKA 1:500/1:15		003	ZAKAZKA Č.	PARÉ
	PSO	01	SO-01	1250	STA			VVV	00
ID STAVBY	STUPEN' DOKUMENT. STAVBY	URČENIE STAVBY	STAVEBNÝ OBJEKT	ID PODLA VÝHLAŽKY	PODOBNE ČÍSLENIE DOKUMENT,	ČÍSLO VÝKRESU	NÁZOV DOKUMENTU	REVIZIA	